



Government of Tripura
Directorate of Fire & Emergency Services
Tripura, Agartala.

Phone: 0381-2326451 Fax: 0381-2324826. Email: dfireservicetripura@gmail.com. Website: www.fireservice.tripura.gov.in

No. 3-8/TFES/2022/ 4186-88

Dated, Agartala, the 12th May, 2022.

To
The Principal,
Don Bosco School,
Dhajanagar, Gokulpur, Udaipur, Gomati, Tripura.

Subject: - Issuance of Fire NOC.

Sir/Madam,

With reference to letter dated 12.05.2022, it is hereby certified that the building/premises as per description below has been inspected by the officer concerned of this department on 28.03.2022. In respect of implementation of Fire Safety measures, it was found that said building have complied with the Fire Prevention and Fire Safety requirements in accordance with provisions of the Part-IV of the latest National Building Code, 2016. Therefore, the premises/building is issued Fire NOC with effect from 12-05-2022 for a period of 01 (one) year in cancellation of issued earlier Temporary NOC vide no. 3-8/TFES/2022/2296-98 Dt. 07/03/2022 subject to compliance of the conditions for the validity of Fire NOC.

Name & address of the proposed building/premises :- "Don Bosco School", Dhajanagar, Gokulpur, Udaipur, Gomati, Tripura.

Issued on 12-05-2022 at Agartala.

N.B. Department is switching over offline issuance of NOC to online shortly. Therefore NOC is issued for a period of 01 (one) year. Thereafter, application to be submitted online (www.edistrict.tripura.gov.in) for Fire NOC.

Yours faithfully,


12/05/22
Joint Director,

Tripura Fire & Emergency Services.

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance and exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Copy to:-

1. The Divisional Fire Officer, Gomati District, Udaipur, Tripura for favour of information.
2. The OC, Udaipur F&ES Station for information.