

Government of Tripura
Office of the Executive Engineer,
Udaipur Division, PWD (R&B),
Udaipur Gomati Tripura.

No. F. 2(73)/EE/PWD/UDP/862-63

Dated, Udaipur 14th June, 2021.

To,
The Principal,
DON BOSCO SCHOOL,
Dhajanagar, Gokulpur,
Udaipur, Gomati District, Tripura.

Subject :- Request to issue building safety certificate.

Reference :- Your letter No - Nil Dt: - 11.6.2021.

Sir,

Please refer to above. As per site inspection and as per available record with the school authority a details report is furnished herewith:

1. Design & Drawing supplied by:
Mr. S.G. Karmakar, AMIE(IND)
Registered Consulting Engineer
Silchar (No. 004) on dated: 18.12.1999.
2. Foundation type: - Isolated footing with depth 1.20 m size
4.00x4.60)ft and (4.00x4.60)ft.
3. Building completed during the year 2008.
4. Building is designed as frame structure with G+1(Administrative
Block)(1st floor with GCI/Galvalume Sheet roofing. (G+2)(class
room & hail block).

This is to certify that the present condition of the School Building is found Satisfactory and which may remain valid for next 2(Two) years up to March, 2023.

This is for your kind information and doing the needful please.

Yours faithfully,

(Er. S.K. Datta,

Executive Engineer,
Udaipur Division, PWD (R&B),
Udaipur Gomati Tripura.

Copy to:

- i) The SDO, PWD(R&B), Sub-Division No-II, Udaipur for information. This refers to his letter No.F.Estt-15/ SDO/PWD/SD-II/UDP/140-41 Dt: - 14.6.2021.
- ii) Office copy.

//
Executive Engineer,
Udaipur Division, PWD (R&B),
Udaipur Gomati Tripura.

Government of Tripura
Office of the Sub-Divisional Officer
Sub-Division No-II, PWD(R&B)
Udaipur, Gomati, Tripura.

File No. ~~Est-15~~/SDO/PWD/SD-II/UDP/UDP/ 140-4,

Dt: 14/06/2021.

To
The Executive Engineer,
PWD(R&B), Udaipur Division,
Udaipur, Gomati, Tripura.

Subject: Submission of verification report on Don Bosco School at Dhajanagar, Udaipur.

Ref:-Letter No:- NIL Dt: 11/06/2021. Of The Principal, DON BOSCO School, Udaipur-799114.

Sir,

Please find herewith the report as per available record with the school Authority and sending on the visible physical inspection conducted today i.e 14/06/2021 of Don Bosco School building situated at Dhajanagar, Udaipur, Gomati, Tripura.

Report is furnished below:-

i) Design & Drawing supplied by:

Mr. S.G Karmakar, AMIE(IND)
Registered Consulting Engineer
Silchar(No.004) on dated:18/12/1999.

ii) Foundation type: Isolated footing with depth 1.20m. size(4.00x4.60)ft.
(4.60x4.60)ft.

iii) Building completed during the year 2008.

iv) Building is designed as frame structure with G+1(Administrative Block)(1st Floor with GCI/Galvalume Sheet roofing)
G+2(class room & hall block)

The present condition of the school building is found satisfactory.

This is for favour of your kind information and further necessary action please.


Enclose The Original Letters of The Principal,
Don Bosco School, Udaipur- 799114.

Yours Sincerely

Sub-Divisional Officer
Sub-Div No-II, PWD(R&B)
Udaipur, Gomati, Tripura.

Copy to:

✓ i) The Principal, Don Bosco School, Dhajanagar, Udaipur, Gomati, Tripura for kind information.


14/06/2021
Sub-Divisional Officer
Sub-Div No-II, PWD(R&B)
Udaipur, Gomati, Tripura.